

The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program
250 Washington Street, Boston, MA 02108-4619
Phone: 617-624-5757 Fax: 617-624-5777
TTY: 617-624-5286

CHARLES D. BAKER
Governor

KARYN E. POLITO
Lieutenant Governor

MARYLOU SUDDERS
Secretary

MONICA BHAREL, MD, MPH
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

October 9, 2015

Frank G. Cousins, Jr., Sheriff
Essex County Women in Transition
20 Manning Avenue
Middleton, MA 01949

Re: Facility Inspection – Essex County Women in Transition, Salisbury

Dear Sheriff Cousins:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Minimum Requirements for the Management of Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; 105 CMR 520.000 Labeling; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Essex County Women in Transition on September 17, 2015 accompanied by Christine Arsenault, Assistant Superintendent, Director. Violations noted during the inspection are listed below including 4 repeat violations:

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

Hallway

No Violations Noted

Office (2)

No Violations Noted

Program Coordinator's Office (3)

No Violations Noted

Deputy Superintendent's Office (4)

No Violations Noted

Laundry Room (5)

105 CMR 451.353*

Interior Maintenance: Washing machine # 1 out-of-order

Staff Bathroom (6)

No Violations Noted

Copy Room (7)

No Violations Noted

Hot Water Heater Room (8)

105 CMR 451.353

Interior Maintenance: Standing water under water heater

HSU (9)

No Violations Noted

Communication Room (10)

No Violations Noted

Visitor's Bathroom (12)

105 CMR 451.123

Maintenance: Wall vent dusty

Dorm Rooms

105 CMR 451.322*

Cell Size: Inadequate floor space in all dorm rooms

Dorm Room # 11

No Violations Noted

Dorm Room # 13

105 CMR 451.123

Maintenance: Bathroom floor tiles loose

Dorm Room # 14

No Violations Noted

Dorm Room # 15

105 CMR 451.353

Interior Maintenance: Window screen dirty

Dorm Room # 16

No Violations Noted

Dorm Room # 17

No Violations Noted

Shower Room (18)

105 CMR 451.130

Hot Water: Shower water temperature recorded at 118°F

Kitchen (19)

FC 6-501.11*

Maintenance and Operation; Repairing: Facility not in good repair, floor tiles damaged near ice machine

FC 3-302.12*

Preventing Food and Ingredient Contamination: Unlabeled food containers

Meeting and Dining Room (20)

105 CMR 451.353

Interior Maintenance: Floor tiles damaged near emergency exit

Observations and Recommendations

1. The inmate population was 22 at the time of inspection.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.


To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "[1999 Food Code](#)".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "General Food Regulations" click "105 CMR 520.000: Labeling."

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,

A handwritten signature in blue ink, appearing to read 'J. Brown', with a long horizontal line extending to the right.

Jonathan Brown
Environmental Health Inspector, CSP, BEH

cc: Jan Sullivan, Acting Director, BEH
Steven Hughes, Director, CSP, BEH
Jay Youmans, Director of Government Affairs
Marylou Sudders, Secretary, Executive Office of Health and Human Services
Carol Higgins O'Brien, Commissioner, DOC
Michael Marks, Superintendent
Elizabeth Gilmartin, EHSO
John Morris, CHO, Director, Salisbury Health Department
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Daniel Bennett, Secretary, EOPSS